



ELECTRIC EXIT DEVICE KIT INSTALLATION INSTRUCTIONS AUTHORIZED EGRESS

K-129 FALCON 24 AND 25 SERIES

MONITORS THE USE OF THE PUSHBAR

Electrical Specifications:

SPDT Monitor Switch
Contacts Rated: 3A @ 125VAC
2A @ 30VDC

Wire Color Codes:

YELLOW - Common
RED - Normally Open
GRAY - Normally Closed

Installation:

1. Separate the channel from the pushbar assembly.
2. Remove the rear pin securing the pushbar assembly to the sub-plate and elevate the rear of the pushbar assembly.
3. Locate the K-129 Kit between the sub-plate and the pushbar assembly.
4. Lower the pushbar assembly back into position and replace the rear pin to secure the pushbar assembly to the sub-plate. Verify the tabs of the pushbar assembly linkage are between the tabs of the switch bracket.
5. Route the lead wires along the outside edge of the pushbar assembly.
6. Attach the channel to the pushbar assembly.
7. Secure the lead wires to the inside of the channel using the supplied ty-wrap mount and ty-wrap.

